



NOTES:

1. LOCATION, TYPE, AND INSTALLATION OF BACKFLOW ASSEMBLY SHALL BE APPROVED BY THE DISTRICT INSPECTOR.
2. ALL PIPE SHALL BE CML & C STEEL, SCHEDULE 40 CEMENT LINED STD. STEEL, OR DUCTILE IRON W/ FLANGED D.I. FITTINGS. CONTRACTOR SHALL PAINT ALL ABOVE GROUND APPURTENANCES WITH ONE COAT OF PRIMER AND 2 COATS OF ALMOND RUST-OLEUM OR FIRE DEPARTMENT APPROVED COLOR.
3. RESILIENT SEATED GATE VALVES AND TEST COCKS REQUIRED.
4. GATE VALVES TO BE CHAINED AND LOCKED IN THE OPEN POSITION AT ALL TIMES WHEN THE SERVICE IS ACTIVATED.
5. PIPE SUPPORTS AS REQUIRED FOR 3" AND LARGER ASSEMBLY. PIPE SUPPORT PER CVWD STD. DWG. 305, OR APPROVED EQUAL.
6. ALL ASSEMBLIES USC, FCC&HR APPROVED.
7. ALL PIPING BETWEEN MAIN AND BACKFLOW ASSEMBLY TO BE FLUSHED BEFORE BACKFLOW IS INSTALLED AND WITNESSED BY DISTRICT INSPECTOR.
8. N-SHAPE ASSEMBLY 12" CLR. TO BOTTOM OF HAND WHEEL.

Cucamonga Valley Water District

FIRE SERVICE BACKFLOW ASSEMBLY



**Cucamonga Valley
Water District**

ENGINEERING DEPARTMENT
10440 ASHFORD STREET, RANCHO CUCAMONGA, CA 91729
(909) 987-2591

APPROVED BY:

John Bosker
JOHN BOSKER P.E., DIRECTOR OF OPERATIONS &
ENGINEERING

6-11-09

DATE

STD. DWG.

110

SHT. 1 OF 1

REV.	DESCRIPTION	DATE	APP'D